



Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|-------------------|-------------------|-------------|---------------------------|-------------|
| afp - 3552 | 19-Nov-2020 | Number 6 | Issue date 19-Jul-2024 | 30-Apr-2025 |

Page 1 of 2

Product designation

Amptech, AT Series, sealed (valve regulated), lead acid batteries

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Supercharge Batteries Pty Ltd
No. 1a Reconciliation Rise, PEMULWUY, NSW, AUSTRALIA, 2145

Registrant

Supercharge Batteries Pty Ltd
No. 1a Reconciliation Rise, PEMULWUY, NSW, AUSTRALIA, 2145

Producer

Shenzhen Ritar Power Co., Ltd.
Bldg 9, Area-2, Fuqiao Industrial Zone, Fuyong Town, BAOAN DISTRICT, SHENZHEN, CHINA, 518103

Conformance criteria and evaluation

The Amptech, AT Series, sealed (valve regulated), lead acid batteries have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. CSIRO Technical Specification TS-015, Version 1,07-Nov-2022, 'Verification of conformity of valve regulated sealed lead-acid (VRSLA) batteries for FDCIE/EWCIE.'

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

| | | | | |
|-------------------|-------------------|-------------|---------------------------|-------------|
| Certificate num. | Registration date | Version | Valid until | |
| afp - 3552 | 19-Nov-2020 | Number 6 | Issue date 19-Jul-2024 | 30-Apr-2025 |

Page 2 of 2

Producer's description

The Amptech, AT Series, sealed (valve regulated), lead acid batteries are for application in cyclic service with repeated charges and discharges, or standby use in which the battery is normally maintained in a charged state and discharged only when required.

Unless stated otherwise by the manufacturer, the batteries are maintenance-free and can be operated and stored in both horizontal and vertical position. The batteries contain no free electrolyte, and gas generated from water electrolysis by overcharging is absorbed by the electrodes and not expelled by the battery, under normal operation.

Technical specification

The following details are a representative extract of the technical specification for the Amptech, AT Series, sealed (valve regulated), lead acid batteries and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

| Model number | Nominal voltage (V) | 20 hr rated capacity (ah) | Length (mm) | Width (mm) | Height (mm) | Total height (mm) | Approx. Weight (kg) |
|--------------|---------------------|---------------------------|-------------|------------|-------------|-------------------|---------------------|
| AT1270P | 12 | 7.0 | 151 | 65 | 94 | 100 | 1.95 |
| AT1290DP | | 9.0 | 151 | 65 | 94 | 100 | 2.30 |
| AT12180DP | | 18.0 | 181 | 77 | 167 | 167 | 6.00 |
| AT12750DP | | 80.0 | 260 | 169 | 211 | 216 | 22.5 |
| AT12900DSP | | 100.0 | 306.5 | 168.5 | 210 | 215 | 30.0 |
| AT121000DSP | | 120.0 | 328 | 172 | 215 | 220 | 32.0 |

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

| Reference | | Title / description | Date issued (or date validated) | Source |
|----------------|--------------------------|---|---------------------------------|---|
| Ident. type | Ident. | | | |
| Report number | XF2428/R2 | Evaluation for Conformity Ritar RT/RA Series Batteries to ActivFire Specification TS-001 | 22-Apr-2010 | CSIRO, Industrial Research Services, AU |
| | CSBA0100/R6 | Verification of Conformity of the Amptech, AT Series, sealed (valve regulated), lead acid batteries to IEC 60896-21:2004 and IEC 60896-22:2004 in accordance with CSIRO Technical Specification TS-015 'Verification of Conformity of Valve Regulated Sealed Lead-Acid (VRSLA) Batteries for FDCIE/EWCIE' Ver 3 (19-Jun-2024) | 5-Jul-2024 | CSIRO Fire Systems Laboratory, AU |
| Correspondence | - | HENGYANG RITAR POWER CO., LTD. AFP – 2422; Request To Include Re-Labelled types | 5-May-2020 | Hengyang Ritar Power Co., Ltd, CN |
| Data sheets | As per Title/description | AMP-TECH Plus Valve Regulated Lead Acid AGM Battery AT1270P AT1290DP AT12180DP AT12750DP AT12900DSP AT121000DSP | 5-Jul-2024 | Supercharge Batteries Pty Ltd, AU |